

Round 2 Source Water Monitoring for the LT2 Rule

The USEPA requires water suppliers to monitor their raw source water for the the contaminant *Cryptosporidium* and other microorganisms. The results of the raw source water testing for *Cryptosporidium* will determine if the EPA requires additional treatment because it is more difficult to remove than other microorganisms.

Date	<i>Cryptosporidium</i> (oocysts/L)	<i>Giardia</i> (cysts/L)	<i>E. coli</i> (MPN/100ml)	Turbidity (NTU)
March 10, 2015	0.100	0.100	12.1	10.6
April 14, 2015	ND*	0.100	28.8	12.6
May 12, 2015	ND*	ND*	727	140
June 9, 2015	ND*	ND*	1200	411
July 14, 2015	ND*	ND*	58.5	119
August 11, 2015	ND*	ND*	436	74.1
September 9, 2015	ND*	0.100	42.2	33.0
October 13, 2015	ND*	ND*	46.5	15.4
November 17, 2015	ND*	ND*	488	23.3
December 8, 2015	ND*	ND*	260	42.0

ND* = Not Detected